

Month	Temp above 83 degrees?	Est. Total hours	Est. Days above 83 degrees	Water demand per month	Unit
Jan	N	0	0	-	gallons/month
Feb	N	0	0	-	gallons/month
Mar	N	0	0	-	gallons/month
Apr	N	0	0	-	gallons/month
May	N	0	0	-	gallons/month
Jun	y	300	14	4,900,000	gallons/month
Jul	y	800	31	10,850,000	gallons/month
Aug	y	400	18	6,300,000	gallons/month
Sep	N	0	0	-	gallons/month
Oct	N	0	0	-	gallons/month
Nov	N	0	0	-	gallons/month
Dec	N	0	0	-	gallons/month
TOTAL		1,500	63	22,050,000	gallons/YEAR

<p>If water is used for 1500 hours/year, that equates to 63 days of water use, mostly during the summer:</p> <p>22,050,000 GPY Annual demand 608 GPM for peak minute demand (assuming a peak factor of 2.5) 36,458 GPH for peak hour demand 875,000 GPD for peak day demand 350,000 GPD average day demand</p>
<p>Assuming 60% of incoming water gets evaporated, 40% turns into blowdown</p> <p>8,820,000 GPY for annual discharge 243 GPM for peak minute discharge 14,583 GPH for peak hour discharge 350,000 GPD for peak day discharge 140,000 GPD for average day discharge</p>

22 million Gallons per year = 67.56 acre/ft per year.